

SUNLAND WATER DISTRICT

Commissioners Meeting

December 2019

Manager’s Report by Mike Langley

~~~~~  
~~~~~

Financial Report by Karen Shay

Water Reclamation Facility

- One of the aerators in the third digester at the WRF was frozen during the cold weather. However, following extraction from the digester, it was found not to be frozen but fouled by a metal identification tag. That’s been removed and the aerator is working fine now.
- The dewatering pump for digesters one and two has failed and Willy is ordering replacement.
- Willy and Rich are continuing remodeling and re-organizing at the WRF lab.
- The crew at the WRF is working on a failed isolation valve for the SBR’s.

Water Meters/Meter Setters

- Scott has completed the water meter reading. The next water meter read is planned for the first week in February.

Water Production/Consumption Results

- The water level in both wells is normal.
- Total water production for November of 2019 from both sources was 6,722,200 gallons, for a total water production in 2019 of 86,621,285 gallons through November. The 2018 total production was 80,964,494 gallons.

Other

- The alarm system for the Taylor lift station has been installed, tested, and is functioning properly. The new lift station is working flawlessly so far.
- This will be another change, as water, power, and sewer are on top of each other there. We'll do some exploratory excavation to find the sewer stub, carefully avoiding the other utilities.
- City of Sequim personnel will be using their snorkel/vac truck to pump out the main lift station at SunLand.
- SWD personnel have been locating District utility lines ahead of the Irrigation District action of piping and covering the irrigation ditch where it passes through Division 17.

