

SUNLAND WATER DISTRICT

Commissioners Meeting

January 2020

Manager's Report by Mike Langley

~~~~~  
~~~~~

Financial Report by Karen Shay

Water Reclamation Facility

- Willy has been working with a software consultant to develop a scada system and replace the paper chart recorders at the WRF.
- Willy is also replacing the old microscope at the WRF.
- Willy and Rich are continuing remodeling and re-organizing at the WRF lab.
- The crew at the WRF is evaluating options for replacing the air blowers for the SBR's. These blowers provide the extra air needed by the bugs consuming the waste.
- And the WRF team is replacing other lab equipment that has passed their end of useful life.

Water Meters/Meter Setters

- Scott has completed the water meter reading. The next water meter read is planned for the first week in March.

Water Production/Consumption Results

- The water level in both wells is normal.
- Total water production numbers will have to wait as we are trying to determine if one of our production meters is giving erroneous readings. The numbers are much higher than expected and we are looking for the cause.

Other

- The battery bank for the emergency generator at the lower reservoir has failed and is being replaced.
- SWD personnel have been winterizing everything to prepare for the forecasted deep freeze in our area.
- The City of Sequim got stuck trying to get close to the main lift station for pumping so this action will have to wait for a dryer time.
- CA Homes is building another house, this one on Williams Place.
- NTI, the engineering firm who did much of the utility design work at SunLand, is going out of business and I was able to visit their "vault" and salvage boxes of files and many drawings.