

SUNLAND WATER DISTRICT

Commissioners Meeting

November 2020

Manager's Report by Mike Langley

~~~~~  
~~~~~

Financial Report by Karen Shay

Water Reclamation Facility

- Willy and Rich are continuing to test for Covid-19 at the WRF. Watch for results of this action on the District web site.
- Straits Electric provided an electrical connection station for a sludge pump at the WRF.
- Willy and Rich have replaced the SBR Decanter wear pads.
- Rocky is now certified as a Wastewater Collection Operator.
- The backhoe has been repaired by SWD personnel.

Water Production/Consumption Results

- The next water meter read is planned for the first week of January. Scott and Rocky have just finished the November water meter read.

- The water level in both wells is normal, up slightly with irrigation season over.
- Total water production numbers continue to appear high. We are continuing to look for leaks or other reasons for high production. Scott is investigating some irrigation that may not be metered

Other

- The emergency generator for lift station #3 will be installed by Straits Electric, Groves Crane, and SWD personnel on Monday, 11/9/2020.
- Al & Nick Friedli of Evolution Controls presented a proposal for a SCADA system to improve the overall efficiency of the equipment at the WRF as well as the replacement of failing equipment.
- Steve Paulson of Olympic Sewer & Drain cleared a sewer line on lot 208.
- The District is advertising for a Water Operator to fill an empty position.