

**SUNLAND WATER DISTRICT**

**Commissioners Meeting**

August 2021

**Manager’s Report by Brian Scott**

~~~~~  
~~~~~

**Financial Report by Karen Shay**

**Water Reclamation Facility**

- Don from DC backflow tested all backflow assemblies in the field and at the plant.
- Evolution Controls set up the computer system at the WRF.
- The control panel and SCADA were updated.
- Replaced filter cloths on the Aqua Disk Filter.
- Biosolids hauling for the month was 9800 @ 2.47% solids.

**Water Production/Consumption Results**

- The next total water meter read will be the first week in September and will be read every month thereafter.
- The water level in both wells is staying about the same as last month as we continue through the irrigation season.
- Total water production numbers continue to appear high. We are continuing to look for leaks or other reasons for high production.

**Other**

- Brian met with Mark Sundt on the lease of the spray field and the set amounts of the lease were agreed upon through 2024.

- Matt with Paco to install the silent check valves on work on the upper reservoir PRV as soon as they come in.
- SWD personnel are in the process of performing a sewer inspection at a new residence on Hogan's Vista.
- Sam and Rocky are both working on the class from WETRC. Sam was approved to take the WDM 2 and CCS test.
- SWD personnel responded to a power outage that occurred on 8/9/21 at 8 a.m.
- SWD personnel are working with J.T. and the PUD on the main lift station.
- Ferguson sent out a rep to talk to Karen about programming. He also met with field staff on the Sensus water meters. The Auto Reader is outdated and can be replaced at low cost for a hand-held device and new wand.
- The SWD purchased a used 2000 Chevy 4wd 1-ton dually service truck for \$12,329.56. The truck is capable of pulling anything the District may have need to tow.