

# **SUNLAND WATER DISTRICT**

## **Commissioners Meeting**

April 19, 2022

### **Manager's Report by Brian Scott**

~~~~~  
~~~~~

### **Financial Report by Karen Shay**

#### **Water Reclamation Facility**

- Willy ordered a new pump for the blower that failed. The new pump turned out to be defective and was returned to the vendor for replacement.
- Rocky replaced the chains on spray line at the plant.
- 16 loads of sludge were taken to the City of Sequim plant equaling 15,400 gallons with 2.73% solids.
- Willy and Rich are working on the O&M report for the DOE due May 15<sup>th</sup>.
- Irrigation fields' monitoring wells were sampled and reported to the DOE.
- Rich did lab performance testing and is waiting for results.

#### **Water Production/Consumption Results**

- The next water meter read will be the first week of May.
- The water level at the lower well is 79 ft. and upper well at 15 ft. Water loss for the month of March = 19%
- Total water production numbers are starting to move up. We are continuing to look for leaks.
- SWD staff worked on cleaning the upper and lower reservoirs. Reports are all good.
- SWD staff are doing a system flash of the waterlines.

- A water staff member was let go by the District Manager on April 13<sup>th</sup> and the SWD is working to fill the vacant position.
- SWD staff is working on the barn between other projects.
- The District Manager attended a Spring Conference presented by the Washington Association of Sewer & Water Districts (WASWD).