

SUNLAND WATER DISTRICT

Commissioners Meeting

July 19, 2022

Manager’s Report by Brian Scott

~~~~~  
~~~~~

Financial Report by Karen Shay

Water Reclamation Facility

- Quarterly testing on irrigation field monitoring wells and sent to the DOE.
- Lab accreditation application sent to the DOE.
- 17 loads of sludge taken to the Sequim plant 8400 gallons - 2.67% solids.
- Brian received his WW Operator 1 Certificate. It is displayed at the WRF and the District Office.

Water Production/Consumption Results

- The next water meter read will be the first week August.
- The water level in both wells: Lower - 77 ft. & Upper - 15.5 ft. Water loss for the month of June was 16%, a drop of 5% from last month. A drop in water loss in the summer is normal due to irrigation.
- Total water production numbers are starting to move up. We are continuing to look for leaks.
- Staff installed the concrete pad for new generator at the lower reservoir.
- The Highway Lift station is being prepped for new pump.
- SWD staff continue to work on barn in between projects.
- Brian submitted the Water Use Efficiency, Consumer Confidence Report and Water Facilities Inventory Update due to the State each year by July 1.
- SWD cleaned and conducted maintenance on all the lift stations.
- SWD received resident complaints about Main Lift Station noise. Staff turned the exhaust to the northwest to see if that helps attenuate the noise factor.