

SUNLAND WATER DISTRICT

Commissioners Meeting

October 18, 2022

Manager's Report by Brian Scott

~~~~~  
~~~~~

Water Reclamation Facility

- Field harvest and crop samples amounted to 55 dry tons.
- Quarterly and yearly monitoring well testing completed.
- 19 loads of sludge (26,600 gallons @ 2.96% solids) went to the Sequim plant.
- A new blower was ordered for the WRF.
- The spray line was oiled.
- Performed maintenance on the ponds and they were washed down.

Water Production/Consumption Results

- The next water meter read will be the first week November.
- The water level in both wells is lower: Upper 77 ft./Lower 15 ft.
- Total water production numbers stayed about the same as last month. Staff continue to look for leaks and bad meters. Water loss is 16% for September.
- SWD staff repaired a leak on Turnagain Place.
- Rocky took monthly samples to the County and sent nitrates from both wells to Spectra.
- The fan at the Upper Reservoir was replaced.
- The drywall is up in the barn and staff are taping and mudding the walls.
- The Highway Lift Station should be delivered the 1st week November.
- The ship date for the new generator for the Lower Reservoir is October 21st.
- E.R.P. drinking totes are stored at the Upper Reservoir and are ready to put into service at any time they are needed.