

SUNLAND WATER DISTRICT

Commissioners Meeting

December 20, 2022

Manager’s Report by Brian Scott

~~~~~  
~~~~~

Water Reclamation Facility

- Winterized equipment.
- Received the new dissolved oxygen meter and new flow meter for effluent flow.
- 10 loads of sludge delivered to Sequim plant 14,000 gallons @ 2.2% solids.
- Willy and Straits Electric met to talk about the upcoming blower project at WRF.
- Biosolids for the year are 189,000 gals, 72,835 dry weight, 2.76 percent solids.

Water Production/Consumption Results

- The next water meter read will be the first week Jan.
- The water levels in both wells show little change - upper well at 77 ft., lower well at 17 ft.
- November’s total water production numbers are more than 50% lower than October. Water loss is 10% for November, the lowest YTD for 2022. We are continuing to look for leaks and bad meters.
- SWD staff received and installed the lower reservoir generator this month.
- Rocky took monthly samples to the county lab this week.
- SWD staff cleaned the Taylor lift station pump which was full of rags and bags.

- SWD staff is getting ready for HWY lift station that shipped. Lift station is scheduled to be here beginning of Jan.
- SWD staff fixed service line that was cracked at 162 Fairway Dr.
- 121 Fairway Dr plugged gutters - homeowner was positive it was a water leak in her meter box.
- Steve from Olympic Sewer and Drain ran camera at 103 Prater Pl. to find main sewer line.
- Work on the new office room and barn is coming along good. Lights, texture, and all plumbing fixtures are in.
- Received Enduris insurance claim funds of \$1,986.50 for upper reservoir roof damage during the wind storm. Total cost to remove trees and fix the roof will be \$2,986.50, but we had a \$1,000 deductible.



