

SUNLAND WATER DISTRICT

Commissioners Meeting

January 2023

Manager’s Report by Brian Scott

~~~~~  
~~~~~

Water Reclamation Facility

- Irrigation test wells were sampled and reported to the State.
- The WRF received an extra 200,000 gallons in one week due to snow melt this month.
- Trenched and installed conduit for new flowmeter replacement for Class A.
- Dewatered #3 digester to thicken biosolids for hauling to City of Sequim.

Water Production/Consumption Results

- The next water meter read will be the first week in February.
- The water levels in both wells show little change - upper well at 77.5 ft., lower well at 17 ft.
- Total water production numbers are down from last month. Water loss is 9% for December. We are continuing to look for leaks and bad meters.
- SWD staff and Strait Electric, along with the Cummins technician, hooked up the new lower reservoir generator and it is up and running.
- Rocky took monthly samples to the county lab this week.
- The HWY lift station was delivered January 18th.
- The SWD District Manager sent a certified letter to 185 Sunset Place regarding the property line dispute.
- McCreary and Sons Roofing will begin repair of the upper reservoir roof on January 30th.