

SUNLAND WATER DISTRICT

Commissioners Meeting

April 18, 2023

Manager's Report by Brian Scott

~~~~~  
~~~~~

Water Reclamation Facility

- Twenty-four (24) loads of sludge (bio-solids), 33,600 lbs., were delivered to the City of Sequim's plant @ 2.63% solids.
- The new Blower is here awaiting conduit placement by the electrician.
- A new dissolved oxygen probe was installed for the new blower.
- Rich did a performance lab accreditation and passed.

Water Production/Consumption Results

- The next water meter read will be the first week in May.
- The water levels in both wells show some change - upper well at 79.5 ft., lower well at 19 ft – up about a foot.
- Total water production numbers are down from last month. Water loss is 12% for March. We are continuing to look for leaks and bad meters.
- Rocky took monthly samples to the county lab last week and all passed.
- Rocky and Brian will be taking a class in Shelton on PFAS May 8th. *(PFAS = PolyFluoroAlkyl Substances (PFAS) are a family of chemicals used since the 1950s to manufacture stain-resistant, water-resistant, and non-stick products. Over time, some PFAS released from manufacturing sites, landfills, and other products seep into surface soils. From there, PFAS leaches into groundwater and can contaminate drinking water.)*
- SWD staff cleaned and filled the lower reservoir as part of annual maintenance and will be cleaning the upper reservoir today, April 18th.
- Ed Mola of Utilities Service Co., Inc. is preparing a bid for the Fawnwood Lift Station.
- The staff will be going to a class on "Call Before You Dig" on Thursday, May 4th.