SUNLAND WATER DISTRICT

Commissioners Meeting

January 2024

Managers' Report by Tim Berger

Water Reclamation Facility

The WRF treated influent flows of over 200,000 gallons on 1/10/24 due to heavy rains.

Water Production/Consumption Results

- 1) Staff installed a new sample station in the utility easement at 122 Horizon View Drive. The owner of the lot was notified. The previous sample station at 130 Horizon View was removed. It was overgrown with vegetation and tree roots and some corrosion was found which could possibly be the cause of contamination issues. SWD staff are implementing a new sampling plan and sample station options are being investigated.
- 2) Water loss for the month was 5%.
- 3) A new covered entryway was installed over the service door to the barn offices to prevent water from entering under the doorway and to keep the siding dry.
- 4) Three (3) estimates were received for recoating the upper reservoir walls. Doing a complete job would be way over budget at \$100,000+. A partial job, including removal of all floor epoxy, spot repairing walls, and recoating all surfaces would be around \$70,000.
- 5) Staff are rebuilding the small Pressure Reducing Valve at the upper reservoir this week.