

# SUNLAND WATER DISTRICT

## Commissioners Meeting

May 2024

### Managers' Report by Tim Berger

#### Water Reclamation Facility

- In the late afternoon/early evening of April 22<sup>nd</sup>, or the early morning hours of April 23<sup>rd</sup>, someone cut the chain from the front gate of the plant. It appears there were no attempts at accessing any buildings, and nothing is missing. Clallam County Sheriff's office will patrol area more frequently during evening and overnight hours. Obtaining quote from Hi-Tech to install two cameras at the WRF.
- Hi-Tech price quote for 2 cameras, mounting, and getting system up and running is \$2,345.76.
- Storage building schematic: Looking at design/build requirements from the Washington State Project Review Committee.
- Fawnwood Lift Station electrical wiring and panel replacement awarded to Johnson Electric.

#### Water

- Valve exercise and hydrant flushing completed on 5/7/24. Water flushed was metered, with a total of 94,817 gallons flushed. With 11.1 miles of 6" mainline, the gallon capacity would be approximately 86,153 gallons, or about 110% of the water in the pipelines flushed.
- Potholing for one new fire hydrant this week. Plan is going forward.
- Water loss for the month held steady at 7%.
- 5/14/24: Water break reported in front of 179 Sunland Drive. Water coming up from under asphalt; service line compromised.
- Lead/galvanized service line inventory documents should be completed by the end of this month and sent to the Department of Health.