



Commissioner's Meeting

June 17, 2025

MANAGERS' REPORT BY TIM BERGER

Water Reclamation Facility

- 5/20/25 Zenovic Engineering reported Clallam County planning and building departments are good with an ecology block retaining wall and curtain drain plans.
- 6/2/25 – Chris from PermaBilt visited the plant to look over building site preparations and make recommendations. He liked preparations accomplished and commented that everything looked on track.
- Willy reminded me that we will not need to order a replacement plug valve for the digesters because the valve being replaced still works.
- Double-check backflow prevention assemblies are being installed at Fawnwood, Taylor, and Highway Lift Stations.

Water

- 6/17/25 Sequim VAC/JET (vactor) truck onsite at 102 Harleman Drive to excavate for hydrant replacement.
- 5/28/25 – Interviewed three candidates for the water apprentice position. All three candidates were qualified for the position. Extended a job offer to David Gardner and he accepted. He will start work on June 24th.
- Rocky is working on building emergency water tote stands at each reservoir.
- Scott and Joe are removing overgrown plants blocking access to fire hydrants and painting faded hydrants.
- Water loss for the month was 5%, down 5% from the previous month. Rocky assisted SunLand pool staff filling their swimming pool. 62,000 gallons metered from the fire hydrant.
- Scott suggested hooking up a security camera in the barn office and storage areas, and installing a smoke detector in the office tied to the alarm system. (Have it monitored with the office contract?) Scott says he could do the work. Comments!!!