



## Commissioner's Meeting July 15, 2025

### MANAGERS' REPORT BY TIM BERGER

#### Water Reclamation Facility

- 7/15/25 – Willy, Rich, and Pat are working on installing second replacement plug valve to the digesters.
- Contractor hit our sewer main while excavating for a sewer stub at 112 Hogans Vista. It was not a big issue. The contractor purchased repair parts and Joe and Rocky installed them. (Locate was off a bit.)
- The power breaker to the mixer in the influent basin needs to be replaced. It trips and does not throw an alarm. Cost to replace is about \$1500. Replacement can be done on site.
- We are still working to find a roofer to replace the lab and chlorine building feed roofs. 4x4 Xterior Roofing has not been returning calls/texts.
- 7/9/25 – Parrish Plumbing was on-site for the semi-annual jetting of the swale on Fairway Drive.
- All the lab certifications submitted by Rich to the DOE were passed! We are good for another year.

#### Water

- 6/24/25- A new fire hydrant was installed at 102 Harleman Drive. Installation went smoothly and the crew feels confident about replacing the next hydrant in-house. There was no disruption of water service to residents during the work.
- 6/24/25- SWD's new apprentice, David Gardner, started work. District staff are pleased with his performance thus far.
- Division 7 is mulling over options regarding metering irrigation systems using unaccounted-for water.
- 6/25/25- Hi-Tech Security was on-site to provide an estimate on a base security system for the barn. 7/8/25. Their quote was \$ 950.00 installed. PTO →



- 

- 7/2/25 – We received a confirmation letter from the DOH stating our lead service line inventory meets all requirements and no further action is needed
- 7/14/25 – Collected and delivered VOC well samples to Spectra Labs in Poulsbo.
- June water loss was 1%.
- The Small Water System Management Plan is close to being completed.