



Commissioner's Meeting December 16, 2025

MANAGERS' REPORT BY TIM BERGER

Water Reclamation Facility

- The new storage building almost complete, with the exception of the front apron. Should be completed once the rain slows down.
- 11/20/25 – The nearly new Polaris ATV has been delivered to the WRF.
- 12/11/25 – Met with John Cristiansen from the City of Sequim to work out a basic framework for an ILA agreement for both water and waste treatment. John will present to the City's legal team for approval before moving to the next step.

Water

- 110 Ridgetop Place – The water team identified a water leak from a consumption report of 35 gph or 25,000 gallons per month. Advised customer to investigate and repair, or get a plumber to repair.
- Scott working on grinding off rust spots and then applying new epoxy on upper reservoir booster pump skid.
- 109 Horizon View – Water team identified a water leak from a consumption report of over 100 gph or about 80,000 gallons per month. Notified homeowner of a steady stream of water going through sewer cleanout, and to get a plumber to repair.
- 12/7/25 – 12:30 am – Power outage due to a power pole being hit on Woodcock Rd and Wilcox. Lower reservoir, all lift stations without power. Scott, Rocky & Joe onsite to manage generators, reservoir booster pump skids and lift stations.
- Water loss for the month was 9%, up from 4% last month. Seasonal increase due to lower consumption.



- 12/10/25 – The two monthly coliform samples we collected both came back positive. 178 Hurricane Ridge Dr & 152 Hilltop Drive. Investigating possible contamination issues. Got the OK from DOH to collect repeat samples yesterday, with results later today.