



Commissioner's Meeting SEPTEMBER 15, 2026

MANAGERS' REPORT BY ROBERT WHALEN

Water Reclamation Facility

- Willie and Rich have completed working on replacing the gear box and the motor on the Raptor Micro Screen (head works Auger). It is now back in service and working great.
- Quarterly and yearly test well monitoring has been reported.
- Continued building maintenance.

Water

- Crews repaired a service line leak at 190 Cascadia Loop. Estimated water loss of 5,164 gallons
- Crews replaced a service saddle that was leaking at 240 Fairway Dr, during this process a stress fracture occurred in the 6" AC main line. We replaced a 20 ft. section of pipe that ran the length of the concrete driveway. Estimated water loss at 87,350 gallons.
- Crew responded to a water leak on the service line at 174 San Juan. Estimated water loss at 16,588 gallons
- Dave, our water apprentice, passed his WDM 2-IT (Water Distribution Manager in training) exam.
- Installed a new meter and setter for a new house being built at 176 Hurricane Ridge.
- Water loss for the month of August was 5%, up from 1% last month. Static level for August rests at 101.3 ft., down from 100.5 ft. last month, while the pumping level sits at 128.1 ft. down from 126.8 ft. last month.