



Commissioner's Meeting OCTOBER 20, 2026

MANAGERS' REPORT BY ROBERT WHALEN

Water Reclamation Facility

- Final cutting of the spray field has concluded, producing 85 tons of silage.
- Crew worked hard, with the help of ERWOW (Evergreen Rural Water of Washington), to smoke test the sewer collections system on the South side of Taylor Blvd. We will smoke test the North side of Taylor in late October
- Crews removed a root ball from the end of the sewer line on 11th Court in preparation of possible new build on empty lot on Vancouver Pl.
- City of Sequim videoed sewer line from Emerald Drive along the #7 and #8 Fairways. Pipe integrity looks good.
- Rocky removed a root blockage from manhole #64, behind 131 Emerald. Resident called and said they were having a sewer backup issue in their house.

Water

- Crew repaired a service line at 241 Mt. Baker. Estimated water loss of 6,306 gallons. SWD was aware of leak on 9/17, leak was fixed 9/22.
- Crew repaired a service line at 102 Northwestern Pl. This one is the 3rd repair on this service line. SWD will schedule a time to make a permanent repair. Estimated water loss of 3,000 gallons. SWD was aware of leak on 9/23, leak was fixed on 9/24
- Crew repaired a service line at 241 Cascadia Loop estimated water loss of 6,306 gallons. SWD was aware of leak on 10/9, leak was fixed on 10/14.
- SWD purchased a new fleet vehicle, a 2022 Chevrolet 1500 4x4.
- Drained one cell in the lower reservoir, estimated water loss of 10,200 gallons.
- Dug up Hydrant on Clallam Bay St. to gather information on parts needed for replacement. Will replace hydrant soon.
- Water loss for the month of September was 6%, up by 1% from last month. The pumping level sits at 127.9 ft. – up from 128.1 ft. last month.