Commissioner's Meeting
NOVEMBER 17, 2026

MANAGERS' REPORT BY ROBERT WHALEN

Water Reclamation Facility

- New aerator for digester #3 has arrived.
- Lance with Evolution controls has updated turbidity reporting for Department of Ecology (DOE).
- Treatment plant has been winterized.
- Painted test wells out in the field.
- ERWOW returned to finish smoke testing everything North of Taylor BLVD.

Water

- Crew drained one more cell in the lower reservoir. Estimated water loss of 10,200 gallons.10,200 gallons a cell that could not be put into the distribution system.
- Crew attended a Trench Safety class in Port Ludlow.
- Crew replaced a fire hydrant on Clallam Bay. Cut out and replaced an existing 6''x 4'' tee and a 4'' hydrant valve with a 4'' supply with line with a new 6''x 6'' tee and a 6'' valve with a 6'' supply line to the hydrant. Hydrant also has a 12'' extension on it to put it at ground level.
- SWD has winterized all the water meters that needed insulation along with the well piping at the upper Res.